

## 2024年度向け 容量市場メインオークション用調整係数

2020年4月20日  
電力広域的運営推進機関

### <変動電源：太陽光>

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	3.9%	11.8%	10.1%	12.7%	16.4%	13.1%	13.5%	15.8%	6.6%

### <変動電源：風力>

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	23.6%	33.8%	25.3%	28.3%	20.9%	27.5%	20.2%	35.6%	19.2%

### <変動電源：一般水力（自流式）>

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	47.2%	55.8%	58.9%	48.7%	58.1%	52.3%	42.1%	49.8%	37.7%

<安定電源：純揚水 北海道エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	89.9%	85.5%	95.0%	100.0%	100.0%	100.0%	96.7%	92.2%	93.4%	96.7%	96.6%	91.5%
19h	89.9%	85.5%	95.0%	100.0%	100.0%	100.0%	96.7%	92.2%	93.4%	96.7%	96.6%	91.5%
18h	89.9%	85.5%	95.0%	100.0%	100.0%	100.0%	96.7%	92.2%	93.4%	96.7%	96.6%	91.5%
17h	89.9%	85.5%	95.0%	100.0%	100.0%	100.0%	96.7%	92.2%	93.4%	96.7%	96.6%	91.5%
16h	89.9%	85.5%	95.0%	100.0%	100.0%	100.0%	96.7%	92.2%	93.4%	96.7%	96.6%	91.5%
15h	89.9%	85.5%	95.0%	100.0%	100.0%	100.0%	96.7%	92.2%	93.4%	96.7%	96.6%	91.5%
14h	89.9%	85.5%	95.0%	100.0%	100.0%	100.0%	96.7%	92.2%	93.4%	96.7%	96.6%	91.5%
13h	89.6%	85.5%	95.0%	100.0%	100.0%	100.0%	96.7%	92.2%	93.4%	96.7%	96.4%	91.5%
12h	89.0%	85.5%	95.0%	100.0%	100.0%	100.0%	96.7%	92.2%	93.4%	96.7%	95.5%	91.5%
11h	88.0%	85.5%	94.9%	100.0%	100.0%	100.0%	96.7%	91.8%	92.7%	96.2%	94.1%	91.3%
10h	86.7%	84.9%	93.9%	100.0%	100.0%	100.0%	96.7%	90.8%	91.5%	95.0%	92.0%	90.4%
9h	85.1%	83.7%	91.9%	100.0%	100.0%	100.0%	96.1%	89.2%	89.6%	93.1%	89.2%	88.7%
8h	83.1%	81.8%	89.0%	99.8%	99.1%	98.5%	94.6%	87.0%	87.1%	90.4%	85.9%	86.4%
7h	80.8%	79.3%	85.1%	96.7%	96.2%	95.3%	92.4%	84.3%	84.0%	87.1%	81.9%	83.4%
6h	78.1%	76.2%	80.2%	92.1%	92.1%	90.8%	89.3%	80.9%	80.3%	83.0%	77.3%	79.6%
5h	75.1%	72.4%	74.4%	86.2%	86.8%	85.1%	85.4%	77.0%	75.9%	78.1%	72.1%	75.2%
4h	71.8%	68.0%	67.6%	78.8%	80.3%	78.1%	80.7%	72.5%	70.9%	72.6%	66.3%	70.1%
3h	68.1%	63.0%	59.9%	70.0%	72.6%	69.8%	75.1%	67.4%	65.3%	66.3%	59.9%	64.2%

<安定電源：純揚水 東北エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	95.0%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	99.3%	99.9%	98.8%	94.0%
19h	95.0%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	99.3%	99.9%	98.8%	94.0%
18h	94.9%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	99.3%	99.9%	98.8%	94.0%
17h	94.7%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	99.3%	99.9%	98.8%	94.0%
16h	94.5%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	99.3%	99.9%	98.8%	94.0%
15h	94.1%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	99.3%	99.9%	98.8%	94.0%
14h	93.6%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	99.3%	99.9%	98.8%	94.0%
13h	93.0%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	99.3%	99.8%	98.6%	94.0%
12h	92.2%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	99.2%	99.4%	98.0%	94.0%
11h	91.4%	90.2%	99.2%	100.0%	100.0%	100.0%	99.9%	96.8%	98.7%	98.6%	96.9%	93.6%
10h	90.5%	90.0%	98.9%	100.0%	100.0%	100.0%	99.9%	96.3%	97.9%	97.4%	95.3%	93.0%
9h	89.4%	89.4%	97.9%	100.0%	100.0%	100.0%	99.7%	95.2%	96.8%	95.9%	93.3%	92.0%
8h	88.2%	88.7%	96.3%	100.0%	100.0%	100.0%	98.9%	93.4%	95.3%	94.1%	90.9%	90.8%
7h	87.0%	87.6%	94.0%	99.7%	99.7%	98.5%	97.6%	91.1%	93.5%	91.8%	88.0%	89.2%
6h	85.6%	86.3%	91.1%	97.1%	97.7%	95.9%	95.7%	88.1%	91.3%	89.3%	84.6%	87.4%
5h	84.1%	84.7%	87.6%	93.6%	94.8%	92.4%	93.3%	84.6%	88.8%	86.4%	80.8%	85.2%
4h	82.5%	82.9%	83.4%	89.1%	91.1%	88.0%	90.3%	80.4%	86.0%	83.1%	76.5%	82.7%
3h	80.7%	80.8%	78.5%	83.6%	86.6%	82.7%	86.8%	75.6%	82.8%	79.4%	71.8%	80.0%

<安定電源：純揚水 東京エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	88.3%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	95.0%	94.2%	97.0%	96.3%	92.3%
19h	88.3%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	95.0%	94.2%	97.0%	96.3%	92.3%
18h	88.3%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	95.0%	94.2%	97.0%	96.3%	92.3%
17h	88.3%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	95.0%	94.2%	97.0%	96.3%	92.3%
16h	88.3%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	95.0%	94.2%	97.0%	96.3%	92.3%
15h	88.3%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	95.0%	94.2%	97.0%	96.3%	92.3%
14h	88.3%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	94.3%	94.2%	97.0%	96.3%	92.3%
13h	88.3%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	92.8%	94.2%	97.0%	96.3%	92.3%
12h	88.3%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	90.6%	94.2%	96.4%	95.7%	91.8%
11h	87.6%	83.5%	94.8%	100.0%	100.0%	100.0%	93.1%	87.6%	94.0%	94.8%	94.1%	90.3%
10h	86.0%	82.8%	93.5%	100.0%	100.0%	100.0%	92.5%	83.9%	92.8%	92.3%	91.4%	87.9%
9h	83.6%	81.0%	90.9%	100.0%	100.0%	99.0%	90.6%	79.4%	90.6%	88.7%	87.8%	84.5%
8h	80.3%	78.0%	86.9%	99.1%	98.0%	95.9%	87.3%	74.2%	87.5%	84.3%	83.0%	80.2%
7h	76.1%	73.9%	81.5%	94.5%	93.4%	90.9%	82.7%	68.2%	83.3%	78.8%	77.3%	75.0%
6h	71.1%	68.7%	74.7%	87.8%	86.8%	84.1%	76.7%	61.5%	78.1%	72.4%	70.5%	68.9%
5h	65.2%	62.4%	66.5%	78.9%	78.3%	75.3%	69.4%	54.1%	71.9%	65.1%	62.8%	61.8%
4h	58.5%	55.0%	57.0%	67.9%	67.7%	64.7%	60.8%	45.9%	64.7%	56.7%	53.9%	53.8%
3h	51.0%	46.4%	46.0%	54.7%	55.1%	52.2%	50.8%	36.9%	56.6%	47.4%	44.1%	44.9%

<安定電源：純揚水 中部エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	89.5%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.3%	96.0%	95.4%	92.9%
19h	89.5%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.3%	96.0%	95.4%	92.9%
18h	89.5%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.3%	96.0%	95.4%	92.9%
17h	89.5%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.3%	96.0%	95.4%	92.9%
16h	89.5%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.3%	96.0%	95.4%	92.9%
15h	89.5%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.3%	96.0%	95.4%	92.9%
14h	89.5%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.3%	96.0%	95.4%	92.9%
13h	89.5%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.3%	96.0%	95.4%	92.9%
12h	89.4%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.3%	96.0%	95.4%	92.9%
11h	88.9%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	92.1%	94.2%	95.4%	94.7%	92.9%
10h	88.0%	86.3%	95.3%	99.8%	100.0%	99.9%	96.1%	91.8%	93.3%	94.0%	93.3%	92.6%
9h	86.8%	85.8%	94.2%	99.8%	100.0%	99.5%	95.7%	90.8%	91.7%	91.8%	91.2%	91.7%
8h	85.2%	84.4%	92.0%	98.6%	98.2%	97.9%	94.5%	88.9%	89.5%	88.8%	88.3%	90.0%
7h	83.2%	82.3%	88.7%	96.1%	94.7%	95.0%	92.4%	86.3%	86.5%	84.9%	84.6%	87.7%
6h	80.8%	79.4%	84.2%	92.4%	89.6%	91.0%	89.4%	82.9%	82.9%	80.3%	80.2%	84.7%
5h	78.1%	75.6%	78.6%	87.3%	83.0%	85.6%	85.5%	78.7%	78.5%	74.7%	75.0%	81.0%
4h	75.0%	71.1%	71.9%	80.9%	74.8%	79.1%	80.8%	73.8%	73.5%	68.4%	69.1%	76.6%
3h	71.5%	65.7%	64.0%	73.1%	65.1%	71.3%	75.2%	68.1%	67.8%	61.2%	62.4%	71.6%

<安定電源：純揚水 北陸エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	91.9%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.6%	98.2%	98.1%	94.9%
19h	91.9%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.6%	98.2%	98.1%	94.9%
18h	91.9%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.6%	98.2%	98.1%	94.9%
17h	91.9%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.6%	98.2%	98.1%	94.9%
16h	91.9%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.6%	98.2%	98.1%	94.9%
15h	91.9%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.6%	98.2%	98.1%	94.9%
14h	91.9%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.6%	98.2%	98.1%	94.9%
13h	91.9%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.6%	98.2%	98.1%	94.9%
12h	91.7%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.6%	98.2%	98.0%	94.9%
11h	91.2%	87.8%	97.2%	100.0%	100.0%	100.0%	98.0%	94.2%	96.5%	98.2%	97.2%	94.9%
10h	90.4%	87.6%	96.7%	100.0%	100.0%	100.0%	98.0%	93.8%	95.9%	97.9%	95.9%	94.6%
9h	89.4%	87.1%	95.6%	100.0%	100.0%	100.0%	97.6%	92.8%	94.8%	96.6%	93.9%	93.7%
8h	88.1%	86.3%	93.8%	100.0%	100.0%	100.0%	96.5%	91.2%	93.1%	94.5%	91.3%	92.3%
7h	86.6%	85.1%	91.3%	100.0%	99.0%	98.0%	94.8%	88.9%	90.9%	91.5%	88.2%	90.3%
6h	84.8%	83.6%	88.1%	96.1%	96.0%	94.0%	92.3%	86.1%	88.1%	87.7%	84.3%	87.8%
5h	82.7%	81.8%	84.2%	90.5%	91.9%	88.8%	89.2%	82.5%	84.8%	83.0%	79.9%	84.8%
4h	80.4%	79.7%	79.6%	83.4%	86.8%	82.3%	85.4%	78.4%	81.0%	77.4%	74.9%	81.2%
3h	77.8%	77.2%	74.4%	74.9%	80.8%	74.6%	80.8%	73.6%	76.6%	70.9%	69.2%	77.1%

<安定電源：純揚水 関西エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	90.0%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	97.0%	96.1%	93.7%
19h	90.0%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	97.0%	96.1%	93.7%
18h	90.0%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	97.0%	96.1%	93.7%
17h	90.0%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	97.0%	96.1%	93.7%
16h	90.0%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	97.0%	96.1%	93.7%
15h	90.0%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	97.0%	96.1%	93.7%
14h	90.0%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	97.0%	96.1%	93.7%
13h	90.0%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	97.0%	96.1%	93.7%
12h	90.0%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	97.0%	96.1%	93.7%
11h	89.9%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.9%	95.2%	96.5%	95.5%	93.7%
10h	89.4%	87.8%	96.5%	100.0%	100.0%	100.0%	97.3%	92.7%	94.9%	95.0%	94.1%	93.7%
9h	88.4%	87.5%	95.4%	100.0%	100.0%	100.0%	97.0%	91.7%	93.8%	92.6%	91.9%	92.9%
8h	87.0%	86.0%	92.9%	100.0%	100.0%	99.2%	95.7%	89.9%	91.9%	89.1%	88.9%	91.3%
7h	85.1%	83.5%	89.0%	98.3%	97.0%	95.9%	93.3%	87.2%	89.2%	84.7%	85.0%	88.9%
6h	82.8%	79.8%	83.7%	93.8%	91.9%	91.2%	89.8%	83.7%	85.7%	79.2%	80.3%	85.6%
5h	80.0%	75.1%	77.0%	87.7%	85.1%	84.9%	85.3%	79.4%	81.5%	72.8%	74.7%	81.6%
4h	76.8%	69.2%	68.9%	80.0%	76.6%	77.2%	79.6%	74.2%	76.5%	65.4%	68.4%	76.7%
3h	73.2%	62.2%	59.4%	70.7%	66.3%	68.0%	72.9%	68.1%	70.7%	57.0%	61.2%	71.1%

<安定電源：純揚水 中国エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	92.6%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	92.0%	94.8%	96.0%	96.5%	92.8%
19h	92.6%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	92.0%	94.8%	96.0%	96.5%	92.8%
18h	92.5%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	92.0%	94.8%	96.0%	96.5%	92.8%
17h	92.3%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	92.0%	94.8%	96.0%	96.5%	92.8%
16h	92.0%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	92.0%	94.8%	96.0%	96.5%	92.8%
15h	91.6%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	92.0%	94.8%	96.0%	96.5%	92.8%
14h	91.1%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	92.0%	94.8%	96.0%	96.5%	92.8%
13h	90.5%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	92.0%	94.8%	96.0%	96.2%	92.8%
12h	89.8%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	92.0%	94.6%	96.0%	95.6%	92.8%
11h	88.9%	85.7%	94.9%	100.0%	99.4%	99.2%	95.4%	91.9%	94.1%	95.6%	94.5%	92.6%
10h	88.0%	85.5%	94.6%	100.0%	99.4%	99.2%	95.4%	91.3%	93.2%	94.7%	92.9%	92.1%
9h	87.0%	85.0%	93.5%	100.0%	99.3%	98.8%	95.0%	90.3%	92.1%	93.1%	91.0%	91.2%
8h	85.8%	84.2%	91.7%	99.4%	98.4%	97.5%	94.1%	88.8%	90.5%	90.9%	88.5%	89.9%
7h	84.6%	83.2%	89.2%	97.5%	96.7%	95.3%	92.6%	86.8%	88.7%	88.1%	85.7%	88.2%
6h	83.2%	81.9%	86.0%	94.5%	94.1%	92.2%	90.6%	84.4%	86.5%	84.7%	82.4%	86.2%
5h	81.8%	80.3%	82.1%	90.5%	90.7%	88.2%	88.1%	81.6%	84.0%	80.8%	78.7%	83.8%
4h	80.2%	78.5%	77.4%	85.5%	86.6%	83.3%	85.0%	78.2%	81.2%	76.2%	74.6%	81.0%
3h	78.6%	76.3%	72.0%	79.4%	81.6%	77.5%	81.5%	74.4%	78.0%	71.0%	70.0%	77.9%



<安定電源：純揚水 四国エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	92.0%	86.5%	95.7%	100.0%	100.0%	100.0%	96.3%	92.8%	95.3%	97.0%	97.5%	93.6%
19h	92.0%	86.5%	95.7%	100.0%	100.0%	100.0%	96.3%	92.8%	95.3%	97.0%	97.5%	93.6%
18h	92.0%	86.5%	95.7%	100.0%	100.0%	100.0%	96.3%	92.8%	95.3%	97.0%	97.5%	93.6%
17h	92.0%	86.5%	95.7%	100.0%	100.0%	100.0%	96.3%	92.8%	95.3%	97.0%	97.5%	93.6%
16h	92.0%	86.5%	95.7%	100.0%	100.0%	100.0%	96.3%	92.8%	95.3%	97.0%	97.5%	93.6%
15h	91.8%	86.5%	95.7%	100.0%	100.0%	100.0%	96.3%	92.8%	95.3%	97.0%	97.5%	93.6%
14h	91.5%	86.5%	95.7%	100.0%	100.0%	100.0%	96.3%	92.8%	95.3%	97.0%	97.5%	93.6%
13h	91.1%	86.5%	95.7%	100.0%	100.0%	100.0%	96.3%	92.8%	95.3%	97.0%	97.2%	93.6%
12h	90.5%	86.5%	95.7%	100.0%	100.0%	100.0%	96.3%	92.8%	95.3%	96.9%	96.5%	93.6%
11h	89.8%	86.4%	95.7%	100.0%	100.0%	100.0%	96.3%	92.7%	95.0%	96.4%	95.3%	93.5%
10h	88.9%	86.1%	95.1%	100.0%	100.0%	100.0%	96.3%	92.2%	94.3%	95.4%	93.8%	93.0%
9h	87.9%	85.6%	94.0%	100.0%	100.0%	99.8%	96.0%	91.2%	93.2%	93.9%	91.8%	92.1%
8h	86.8%	84.9%	92.4%	100.0%	99.3%	98.5%	95.0%	89.7%	91.7%	91.9%	89.4%	90.8%
7h	85.5%	84.0%	90.1%	98.5%	97.6%	96.4%	93.6%	87.8%	89.7%	89.5%	86.6%	89.1%
6h	84.1%	82.9%	87.3%	95.6%	95.3%	93.3%	91.6%	85.3%	87.4%	86.6%	83.4%	87.1%
5h	82.5%	81.6%	83.9%	91.7%	92.2%	89.3%	89.0%	82.4%	84.6%	83.1%	79.8%	84.7%
4h	80.8%	80.1%	80.0%	86.8%	88.3%	84.5%	86.0%	79.0%	81.5%	79.2%	75.8%	81.9%
3h	79.0%	78.3%	75.5%	80.9%	83.7%	78.7%	82.3%	75.2%	77.9%	74.9%	71.4%	78.7%

<安定電源：純揚水 九州エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	90.4%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.4%	97.1%	94.0%
19h	90.4%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.4%	97.1%	94.0%
18h	90.4%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.4%	97.1%	94.0%
17h	90.4%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.4%	97.1%	94.0%
16h	90.4%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.4%	97.1%	94.0%
15h	90.4%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.4%	97.1%	94.0%
14h	90.4%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.4%	97.1%	94.0%
13h	90.4%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.4%	97.1%	94.0%
12h	90.4%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.4%	97.0%	94.0%
11h	90.2%	87.7%	96.5%	100.0%	100.0%	100.0%	98.1%	93.3%	95.8%	97.2%	96.2%	94.0%
10h	89.3%	87.7%	96.0%	100.0%	100.0%	100.0%	98.1%	92.9%	95.2%	96.2%	94.6%	93.7%
9h	87.7%	87.0%	94.5%	100.0%	100.0%	100.0%	97.6%	91.7%	93.9%	94.6%	92.4%	92.5%
8h	85.6%	85.4%	91.8%	100.0%	100.0%	99.8%	95.9%	89.5%	92.0%	92.2%	89.5%	90.6%
7h	82.8%	82.8%	88.1%	99.0%	98.2%	96.6%	92.8%	86.6%	89.5%	89.2%	85.9%	88.0%
6h	79.4%	79.2%	83.2%	94.9%	94.2%	91.9%	88.5%	82.8%	86.3%	85.5%	81.6%	84.5%
5h	75.3%	74.6%	77.3%	89.3%	88.9%	85.8%	82.8%	78.1%	82.5%	81.0%	76.6%	80.2%
4h	70.6%	69.2%	70.2%	82.3%	82.2%	78.2%	75.9%	72.6%	78.1%	75.9%	71.0%	75.2%
3h	65.3%	62.7%	62.1%	73.9%	74.2%	69.2%	67.7%	66.2%	73.0%	70.0%	64.6%	69.4%