

2026年度向け 容量市場メインオークション用調整係数

2022年7月27日
電力広域的運営推進機関

<変動電源：太陽光>

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	3.7%	11.2%	9.7%	12.4%	15.7%	13.2%	12.9%	15.8%	5.5%

<変動電源：風力>

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	21.6%	30.5%	24.5%	27.9%	21.1%	27.0%	20.0%	33.8%	18.8%

<変動電源：一般水力（自流式）>

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	42.9%	54.2%	57.8%	47.0%	54.2%	51.3%	41.0%	49.1%	36.3%

※調整係数は端数処理（小数点第2位を四捨五入）した値を表示していますが、各算定では端数処理前の値を使用します。

<安定電源：純揚水 北海道エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	91.2%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.7%	99.2%	100.0%	95.6%
19h	91.2%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.7%	99.2%	100.0%	95.6%
18h	91.2%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.7%	99.2%	100.0%	95.6%
17h	91.2%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.7%	99.2%	100.0%	95.6%
16h	91.2%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.7%	99.2%	100.0%	95.6%
15h	91.2%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.7%	99.2%	100.0%	95.6%
14h	91.2%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.7%	99.2%	100.0%	95.6%
13h	91.2%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.7%	99.2%	100.0%	95.6%
12h	91.0%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.7%	99.2%	100.0%	95.6%
11h	90.5%	89.0%	96.6%	100.0%	100.0%	100.0%	98.3%	95.9%	99.6%	98.9%	100.0%	95.6%
10h	89.5%	88.6%	95.9%	100.0%	100.0%	100.0%	98.2%	95.5%	98.8%	98.1%	99.3%	94.9%
9h	88.2%	87.5%	94.2%	100.0%	100.0%	100.0%	97.4%	94.4%	97.1%	96.7%	97.6%	93.3%
8h	86.5%	85.8%	91.6%	100.0%	100.0%	98.7%	95.9%	92.7%	94.7%	94.8%	95.0%	91.0%
7h	84.5%	83.5%	88.1%	97.3%	99.2%	96.2%	93.7%	90.3%	91.5%	92.2%	91.6%	87.9%
6h	82.0%	80.4%	83.6%	93.5%	96.2%	92.6%	90.7%	87.3%	87.5%	89.2%	87.4%	84.0%
5h	79.2%	76.8%	78.2%	88.4%	92.1%	88.0%	87.1%	83.7%	82.7%	85.5%	82.3%	79.3%
4h	76.1%	72.4%	71.9%	82.1%	86.9%	82.3%	82.7%	79.5%	77.2%	81.3%	76.4%	73.7%
3h	72.5%	67.4%	64.6%	74.6%	80.7%	75.7%	77.6%	74.6%	70.8%	76.5%	69.6%	67.4%

<安定電源：純揚水 東北エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	91.1%	90.0%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	100.0%	100.0%	96.2%
19h	91.1%	90.0%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	100.0%	100.0%	96.2%
18h	91.1%	90.0%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	100.0%	100.0%	96.2%
17h	91.1%	90.0%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	100.0%	100.0%	96.2%
16h	91.1%	90.0%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	100.0%	100.0%	96.2%
15h	91.1%	90.0%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	100.0%	100.0%	96.2%
14h	91.1%	90.0%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	100.0%	100.0%	96.2%
13h	91.1%	90.0%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	100.0%	100.0%	96.2%
12h	91.1%	90.0%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	99.5%	100.0%	96.2%
11h	91.0%	89.9%	97.4%	100.0%	100.0%	100.0%	98.8%	96.0%	100.0%	98.7%	100.0%	95.8%
10h	90.4%	89.5%	97.0%	100.0%	100.0%	100.0%	98.6%	95.6%	99.9%	97.6%	100.0%	95.0%
9h	89.4%	88.8%	96.0%	100.0%	100.0%	100.0%	97.9%	94.6%	99.3%	96.2%	98.8%	93.9%
8h	88.1%	87.9%	94.3%	100.0%	100.0%	100.0%	96.7%	93.0%	98.1%	94.6%	96.9%	92.5%
7h	86.4%	86.6%	91.9%	99.8%	99.9%	97.9%	95.2%	90.8%	96.4%	92.6%	94.3%	90.6%
6h	84.3%	85.1%	88.9%	97.3%	97.3%	94.9%	93.1%	88.0%	94.2%	90.4%	91.0%	88.4%
5h	81.8%	83.3%	85.2%	93.9%	93.8%	91.0%	90.7%	84.5%	91.5%	87.8%	87.0%	85.9%
4h	78.9%	81.3%	80.8%	89.6%	89.4%	86.2%	87.8%	80.5%	88.3%	85.0%	82.2%	83.0%
3h	75.7%	78.9%	75.8%	84.4%	84.0%	80.5%	84.4%	75.9%	84.5%	81.9%	76.7%	79.8%

<安定電源：純揚水 東京エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	89.6%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	95.7%	100.0%	99.5%	100.0%	95.8%
19h	89.6%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	95.7%	100.0%	99.5%	100.0%	95.8%
18h	89.6%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	95.7%	100.0%	99.5%	100.0%	95.8%
17h	89.6%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	95.7%	100.0%	99.5%	100.0%	95.8%
16h	89.6%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	95.7%	100.0%	99.5%	100.0%	95.8%
15h	89.6%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	95.7%	100.0%	99.5%	100.0%	95.8%
14h	89.6%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	95.7%	100.0%	99.5%	100.0%	95.8%
13h	89.6%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	95.7%	100.0%	99.5%	100.0%	95.8%
12h	89.6%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	94.8%	100.0%	99.5%	100.0%	95.8%
11h	88.7%	89.1%	98.1%	100.0%	100.0%	100.0%	99.8%	92.9%	100.0%	99.0%	100.0%	94.8%
10h	87.0%	88.3%	97.6%	100.0%	100.0%	100.0%	99.8%	90.1%	100.0%	97.3%	100.0%	92.8%
9h	84.4%	86.4%	95.5%	100.0%	100.0%	100.0%	98.4%	86.3%	100.0%	94.4%	99.4%	89.8%
8h	81.0%	83.2%	91.8%	100.0%	100.0%	100.0%	95.5%	81.5%	98.7%	90.2%	96.2%	85.7%
7h	76.7%	79.0%	86.6%	98.7%	98.1%	95.5%	90.9%	75.8%	95.5%	84.9%	91.5%	80.5%
6h	71.6%	73.5%	79.7%	92.8%	92.0%	89.1%	84.8%	69.1%	91.0%	78.3%	85.2%	74.4%
5h	65.6%	66.9%	71.3%	84.8%	83.8%	80.7%	77.2%	61.4%	85.2%	70.5%	77.4%	67.1%
4h	58.7%	59.1%	61.3%	74.9%	73.6%	70.3%	67.9%	52.7%	78.2%	61.5%	68.0%	58.9%
3h	51.0%	50.2%	49.7%	62.8%	61.4%	58.0%	57.1%	43.1%	69.9%	51.2%	57.0%	49.5%

<安定電源：純揚水 中部エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	91.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	99.0%	100.0%	96.0%
19h	91.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	99.0%	100.0%	96.0%
18h	91.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	99.0%	100.0%	96.0%
17h	91.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	99.0%	100.0%	96.0%
16h	91.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	99.0%	100.0%	96.0%
15h	91.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	99.0%	100.0%	96.0%
14h	91.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	99.0%	100.0%	96.0%
13h	91.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	99.0%	100.0%	96.0%
12h	91.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	99.0%	100.0%	96.0%
11h	90.7%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	96.0%	100.0%	98.6%	100.0%	96.0%
10h	90.0%	90.1%	98.1%	100.0%	100.0%	100.0%	99.4%	95.8%	100.0%	97.2%	100.0%	95.6%
9h	88.8%	89.4%	97.1%	100.0%	100.0%	100.0%	98.8%	94.8%	99.7%	94.9%	98.9%	94.5%
8h	87.3%	88.1%	95.1%	100.0%	100.0%	100.0%	97.5%	93.1%	97.5%	91.6%	96.9%	92.8%
7h	85.3%	86.1%	91.9%	99.9%	98.7%	98.0%	95.3%	90.7%	94.2%	87.4%	94.0%	90.3%
6h	82.9%	83.4%	87.5%	96.8%	94.5%	94.2%	92.2%	87.5%	89.6%	82.2%	90.3%	87.3%
5h	80.1%	80.1%	82.1%	92.6%	88.9%	89.2%	88.4%	83.6%	83.9%	76.1%	85.7%	83.5%
4h	76.9%	76.1%	75.5%	87.3%	81.9%	83.0%	83.7%	78.9%	77.0%	69.0%	80.3%	79.1%
3h	73.3%	71.3%	67.8%	80.8%	73.5%	75.5%	78.2%	73.5%	68.8%	60.9%	74.1%	74.1%

<安定電源：純揚水 北陸エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	91.8%	89.9%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.9%
19h	91.8%	89.9%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.9%
18h	91.8%	89.9%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.9%
17h	91.8%	89.9%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.9%
16h	91.8%	89.9%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.9%
15h	91.8%	89.9%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.9%
14h	91.8%	89.9%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.9%
13h	91.7%	89.9%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.9%
12h	91.4%	89.9%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.9%
11h	90.8%	89.8%	97.3%	100.0%	100.0%	100.0%	99.0%	95.9%	100.0%	99.1%	100.0%	95.7%
10h	90.1%	89.3%	96.9%	100.0%	100.0%	100.0%	98.8%	95.3%	99.9%	98.5%	99.6%	95.0%
9h	89.1%	88.6%	95.7%	100.0%	100.0%	100.0%	98.1%	94.3%	99.3%	97.1%	98.4%	93.9%
8h	87.8%	87.7%	93.8%	100.0%	100.0%	100.0%	97.0%	92.8%	98.1%	95.0%	96.5%	92.5%
7h	86.3%	86.5%	91.3%	99.7%	99.6%	98.0%	95.3%	90.7%	96.4%	92.2%	93.9%	90.5%
6h	84.6%	85.1%	88.0%	97.2%	97.9%	95.0%	93.2%	88.2%	94.2%	88.6%	90.7%	88.2%
5h	82.7%	83.4%	84.0%	93.8%	95.5%	91.1%	90.6%	85.2%	91.5%	84.2%	86.9%	85.5%
4h	80.5%	81.5%	79.3%	89.5%	92.6%	86.4%	87.5%	81.7%	88.2%	79.1%	82.5%	82.3%
3h	78.1%	79.3%	73.9%	84.4%	89.0%	80.7%	83.8%	77.7%	84.4%	73.3%	77.4%	78.7%

<安定電源：純揚水 関西エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	99.2%	98.4%	96.1%
19h	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	99.2%	98.4%	96.1%
18h	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	99.2%	98.4%	96.1%
17h	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	99.2%	98.4%	96.1%
16h	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	99.2%	98.4%	96.1%
15h	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	99.2%	98.4%	96.1%
14h	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	99.2%	98.4%	96.1%
13h	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	99.2%	98.4%	96.1%
12h	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	99.2%	98.4%	96.1%
11h	91.0%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.1%	100.0%	98.9%	98.4%	96.1%
10h	90.6%	90.9%	98.6%	100.0%	100.0%	100.0%	99.9%	96.0%	100.0%	97.5%	98.4%	95.8%
9h	89.7%	90.5%	97.6%	100.0%	100.0%	100.0%	99.4%	95.0%	100.0%	95.0%	98.4%	94.8%
8h	88.3%	89.1%	95.2%	100.0%	100.0%	100.0%	97.9%	93.3%	98.5%	91.4%	97.2%	93.0%
7h	86.3%	86.6%	91.3%	100.0%	99.8%	97.9%	95.4%	90.8%	96.2%	86.7%	94.7%	90.5%
6h	83.9%	83.2%	86.0%	96.2%	95.7%	93.5%	91.9%	87.5%	93.1%	80.9%	90.9%	87.2%
5h	80.9%	78.7%	79.4%	90.9%	90.2%	87.6%	87.4%	83.4%	89.1%	74.1%	85.8%	83.1%
4h	77.4%	73.3%	71.2%	84.1%	83.2%	80.3%	81.8%	78.5%	84.3%	66.1%	79.6%	78.3%
3h	73.5%	66.8%	61.7%	75.9%	74.7%	71.5%	75.2%	72.7%	78.6%	57.1%	72.0%	72.7%

<安定電源：純揚水 中国エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	91.8%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	96.0%
19h	91.8%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	96.0%
18h	91.8%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	96.0%
17h	91.8%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	96.0%
16h	91.8%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	96.0%
15h	91.8%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	96.0%
14h	91.8%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	96.0%
13h	91.6%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	96.0%
12h	91.3%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	96.0%
11h	90.8%	89.8%	97.6%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.0%	100.0%	95.8%
10h	90.0%	89.5%	97.5%	100.0%	100.0%	100.0%	98.8%	95.4%	99.9%	98.3%	99.6%	95.2%
9h	88.9%	88.9%	96.5%	100.0%	100.0%	100.0%	98.1%	94.4%	99.3%	96.9%	98.3%	94.1%
8h	87.7%	87.9%	94.6%	100.0%	100.0%	100.0%	97.0%	92.8%	98.1%	94.6%	96.4%	92.6%
7h	86.2%	86.5%	92.0%	99.8%	99.6%	97.9%	95.3%	90.7%	96.4%	91.7%	93.8%	90.7%
6h	84.5%	84.9%	88.5%	97.1%	97.3%	94.9%	93.0%	88.1%	94.2%	87.9%	90.6%	88.2%
5h	82.6%	82.9%	84.1%	93.4%	94.2%	90.8%	90.2%	84.9%	91.4%	83.4%	86.7%	85.4%
4h	80.4%	80.5%	79.0%	88.8%	90.3%	85.8%	86.8%	81.2%	88.2%	78.0%	82.2%	82.0%
3h	78.1%	77.9%	73.0%	83.2%	85.5%	79.9%	83.0%	76.9%	84.4%	72.0%	77.0%	78.3%

<安定電源：純揚水 四国エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	92.5%	90.0%	97.5%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.1%	100.0%	96.1%
19h	92.5%	90.0%	97.5%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.1%	100.0%	96.1%
18h	92.5%	90.0%	97.5%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.1%	100.0%	96.1%
17h	92.5%	90.0%	97.5%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.1%	100.0%	96.1%
16h	92.5%	90.0%	97.5%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.1%	100.0%	96.1%
15h	92.5%	90.0%	97.5%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.1%	100.0%	96.1%
14h	92.3%	90.0%	97.5%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.1%	100.0%	96.1%
13h	92.0%	90.0%	97.5%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.1%	100.0%	96.1%
12h	91.5%	90.0%	97.5%	100.0%	100.0%	100.0%	98.9%	95.9%	100.0%	99.1%	100.0%	96.1%
11h	90.8%	89.8%	97.5%	100.0%	100.0%	100.0%	98.9%	95.8%	100.0%	98.9%	100.0%	95.8%
10h	89.9%	89.3%	97.1%	100.0%	100.0%	100.0%	98.7%	95.3%	99.9%	98.1%	99.6%	95.0%
9h	88.9%	88.6%	96.0%	100.0%	100.0%	100.0%	98.0%	94.2%	99.2%	96.8%	98.3%	93.9%
8h	87.7%	87.7%	94.3%	100.0%	100.0%	99.8%	96.9%	92.7%	98.1%	94.9%	96.4%	92.5%
7h	86.2%	86.5%	91.9%	99.6%	99.3%	97.9%	95.3%	90.7%	96.4%	92.5%	93.8%	90.6%
6h	84.7%	85.1%	88.9%	97.3%	97.3%	95.1%	93.2%	88.2%	94.2%	89.5%	90.6%	88.4%
5h	82.9%	83.4%	85.3%	94.1%	94.6%	91.4%	90.6%	85.2%	91.5%	86.0%	86.8%	85.7%
4h	81.0%	81.4%	81.0%	90.1%	91.2%	86.9%	87.6%	81.7%	88.3%	81.9%	82.3%	82.7%
3h	78.9%	79.2%	76.1%	85.2%	87.1%	81.6%	84.1%	77.8%	84.5%	77.3%	77.1%	79.3%

<安定電源：純揚水 九州エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	90.9%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
19h	90.9%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
18h	90.9%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
17h	90.9%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
16h	90.9%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
15h	90.9%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
14h	90.9%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
13h	90.9%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
12h	90.9%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
11h	90.6%	90.1%	97.8%	100.0%	100.0%	100.0%	99.8%	95.9%	100.0%	99.0%	100.0%	96.0%
10h	89.8%	90.1%	97.6%	100.0%	100.0%	100.0%	99.8%	95.6%	100.0%	98.4%	99.6%	95.7%
9h	88.5%	89.4%	96.5%	100.0%	100.0%	100.0%	99.2%	94.4%	99.9%	97.0%	97.9%	94.6%
8h	86.8%	88.0%	94.3%	100.0%	100.0%	100.0%	97.6%	92.5%	98.7%	95.0%	95.4%	92.7%
7h	84.5%	85.8%	91.0%	99.8%	99.6%	97.9%	95.0%	89.7%	96.6%	92.3%	91.9%	90.0%
6h	81.7%	82.8%	86.7%	96.9%	96.5%	93.9%	91.4%	86.1%	93.8%	88.8%	87.5%	86.5%
5h	78.4%	79.0%	81.3%	92.9%	92.2%	88.8%	86.7%	81.7%	90.2%	84.7%	82.2%	82.3%
4h	74.7%	74.5%	74.9%	88.0%	86.8%	82.3%	81.0%	76.4%	85.9%	79.9%	76.0%	77.3%
3h	70.4%	69.3%	67.5%	81.9%	80.2%	74.6%	74.3%	70.4%	80.8%	74.3%	68.8%	71.5%