

2029年度向け 容量市場メインオークション用調整係数

＜変動電源：太陽光＞

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	4.28160433282539%	10.19440795490020%	9.43766615249122%	10.84521870355900%	14.65563169605410%	11.30380822178770%	12.44511925872570%	13.84699726080490%	6.23677057991483%

＜変動電源：風力＞

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	22.09405802567910%	32.19023479553990%	23.94790558672610%	27.59457524359420%	20.55768845176900%	29.01090568569420%	18.73829753403880%	31.97222935401620%	17.63884006884740%

＜変動電源：一般水力（自流式）＞

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	39.15001218692350%	55.44100461167310%	50.19086795260160%	45.84571472171870%	51.94527469842520%	49.80385229455660%	41.20935138968950%	49.21045742011860%	35.16054946206390%

2025年7月31日
電力広域的運営推進機関

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.73300545137040%	100.00000000000000%
19h	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.73300545137040%	100.00000000000000%
18h	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.73300545137040%	100.00000000000000%
17h	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.73300545137040%	100.00000000000000%
16h	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.73300545137040%	100.00000000000000%
15h	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.73300545137040%	100.00000000000000%
14h	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.73300545137040%	100.00000000000000%
13h	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.73300545137040%	100.00000000000000%
12h	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.73300545137040%	100.00000000000000%
11h	100.00000000000000%	99.30031205363620%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	99.45805453257980%	100.00000000000000%
10h	100.00000000000000%	99.19040400132360%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.92788022021300%	100.00000000000000%	98.28122555191010%	100.00000000000000%
9h	99.69505448046810%	98.34472850836900%	99.11651227684630%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.78808571176770%	99.12954857728240%	100.00000000000000%	96.20251850936130%	100.00000000000000%
8h	98.48666113597320%	96.76328557477220%	97.02045294438370%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.28875464724340%	97.42801564234930%	98.49695519488960%	93.22193340493350%	100.00000000000000%
7h	96.69076881937670%	94.44607520053330%	93.81868400418850%	99.93195407846520%	99.62942900790340%	98.79835699249930%	99.75792010554840%	95.94386762927640%	94.82328141541370%	95.950304444467270%	89.33947023862670%	98.90717266668950%
6h	94.307377534278											

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	99.85900023424070%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.95176947889020%	99.23961909525710%	100.00000000000000%
9h	99.49089781579850%	99.24834931190430%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.35705978243510%	99.32826249594440%	100.00000000000000%
8h	98.39082438915590%	98.16971018811330%	99.37259698159510%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.31718555420050%	97.73384190623640%	98.26370242865080%	95.42766425711260%	100.00000000000000%
7h	96.81322840159270%	96.62308286286770%	96.35139871511240%	99.96330523501570%	99.60528169476490%	99.49272195968240%	99.53410102867160%	97.57878348550720%	95.36650348825840%	96.75808927700950%	92.47721903014610%	99.44249072647160

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.87750214706980%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.87750214706980%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.87750214706980%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.87750214706980%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.87750214706980%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.87750214706980%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.87750214706980%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.87750214706980%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.83583724868930%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.58390212377740%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	96.12169677233410%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
9h	100.00000000000000%	99.24956488102730%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	92.44922119435920%	100.00000000000000%	98.07859137348600%	99.26779046292210%	100.00000000000000%
8h	100.00000000000000%	95.44862869404940%	98.70640293182840%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	87.56647538985280%	97.69782212135400%	94.77886379768970%	96.04942866271240%	100.00000000000000%
7h	96.71547678956630%	89.7823276051200%	93.43941737039570%	100.00000000000000%	99.52975484267290%	98.65094760012660%	99.17607970060160%	81.47345935881500%	93.17836731089870%	90.12704084097070%	91.24028986565050%	96.27937699759780%

2029年度向け 容量市場メインオークション用調整係数

2025年7月31日
電力広域の運営推進機関

＜安定電源：純揚水 中部エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33778679317710%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33778679317710%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33778679317710%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33778679317710%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33778679317710%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33778679317710%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33778679317710%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33778679317710%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33778679317710%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.83938333055040%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.26016602605070%	99.50071314029190%	100.00000000000000%
9h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.67505591786210%	94.60013487967790%	98.0108248877210%
8h	98.51196244076880%	99.60776049484870%	99.72366401703760%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.23641532152840%	98.0380172211300%	90.85928989143210%	95.72116819480790%	100.00000000000000%
7h	95.79791394195410%	96.72265940627840%	96.29797714989210%	100.00000000000000%	99.93480030323510%	99.26442828361170%	99.59448278593080%	97.45910157884360%	95.47484255463780%	86.03763106131330%	92.63174485623930%	99.42353969889240%
6h	92.07577416740640%	92.56038302238070%	91.38136960158480%	97.41882515012890%	96.57559873332210%	95.89041301074200%	96.93109422098940%	94.95559661478190%	92.08817841543630%	80.13515838932140%	88.74255427522620%	96.62524926052640%
5h	87.34554311712580%	87.12093134315550%	84.97384137211580%	93.76495496518600%	91.97961000687050%	91.33816659284650%	93.32099380625820%	91.72590042934310%	87.84380930450870%	73.15187187545650%	84.05359645104870%	92.84442058579610%
4h	81.60722079111210%	80.40430436860280%	77.07539246148510%	89.11616926145170%	86.14683412388040%	85.60768902992520%	88.76418154173740%	87.77001302252740%	82.74173522185490%	65.08777151971850%	78.56487138370670%	88.08105367470140%
3h	74.86080718936540%	72.41050209872270%	67.68602286969270%	83.47246803892600%	79.07727108435170%	78.69898032197800%	83.26065742742680%	83.08793439433460%	76.78195616747480%	55.94285732210750%	72.27637907320030%	82.33514852724240%

＜安定電源：純揚水 北陸エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.86545396113940%	100.00000000000000%	99.87216603124930%	100.00000000000000%
10h	99.93492083616580%	99.89926342124250%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.69616394565280%	100.00000000000000%	98.91103592621920%	100.00000000000000%
9h	99.27993026525670%	99.27785456208980%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	96.82368667001320%	99.66183505128130%	97.33033456780420%	100.00000000000000%
8h	98.17188302446590%	98.21916469290150%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.19824237386200%	95.24802213422050%	98.58889869196700%	95.1306195600410%	100.00000000000000%
7h	96.61077911379360%	96.72319381367790%	97.27599760610110%	100.00000000000000%	99.88687518511690%	99.39428266391580%	99.57194598915610%	97.45974289101190%	92.96917033827490%	97.02698456465460%	92.3102180981900%	99.44540319118480%
6h	94.59661853323960%	94.78994192441880%	90.66875902246000%	97.73945066550930%	97.20774792910040%	95.56112096782920%	96.99888362217210%	95.02463960735180%	89.98713128217620%	94.97609266934390%	88.87080297224880%	96.99948159000240%
5h	92.12940128280400%	92.41940902512430%	81.83124206394400%	94.42007633921250%	93.54939208104060%	90.36593474497600%	93.51591005259930%	91.89293252288180%	86.30190496592450%	92.43622300603500%	84.81181660029360%	93.69996320493860%
4h	89.20912736248680%	89.61159511579440%	70.76344673055320%	90.19310688644280%	88.91180764093730%	83.80872399535640%	89.12302528043760%	88.06462163760190%	81.91349138951980%	89.40737557472790%	80.13325897495340%	89.54684803599330%
3h	85.83579677228800%	86.36650019642910%	57.46537302228750%	85.05854230720030%	83.29499460879050%	75.88948871897020%	83.82022930568700%	83.53970695151220%	76.82189055296210%	85.88955037542260%	74.83513009622820%	84.54013608316660%

＜安定電源：純揚水 関西エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.83515687165570%	100.00000000000000%
9h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.91736065800620%	98.83534605826420%	98.37702503937240%
8h	98.89406046255040%	100.00000000000000%	99.93861381758580%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.90622780735040%	98.13641614390840%	96.37485678354620%	95.94941387615500%	100.00000000000000%
7h	97.00243036748840%	96.95988371595290%	96.15735391236180%	100.00000000000000%	100.00000000000000%	99.34932120666760%	99.61138832784480%	97.64408994719460%	95.39149563547960%	92.78326890779030%	88.5523238203050%	99.549635659

2029年度向け 容量市場メインオークション用調整係数

2025年7月31日
電力広域の運営推進機関

＜安定電源：純揚水 中国エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	99.91638565631220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.31522497970160%	100.00000000000000%
9h	99.36354050157830%	99.36572266152570%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.33929497232730%	99.96013503316020%	97.77206313936060%	100.00000000000000%
8h	98.25846601246790%	98.26039913468670%	99.33865904642750%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.26048318057240%	97.70621120967730%	98.59208476714570%	95.50920424433570%	100.00000000000000%
7h	96.69899143733600%	96.60041507579530%	96.31116094387770%	100.00000000000000%	99.94666948193420%	99.18350275302890%	99.54496106743810%	97.48153306036800%	95.29302347503140%	96.47304887763180%	92.5266482962680%	99.44838665096210%
6h	94.68511677618250%	94.38577048485140%	92.02270574899950%	97.54861009928750%	96.87879353137960%	96.17642733447340%	96.95574951630460%	94.97530276161410%	92.09973176838950%	93.60302736461850%	88.82439529023390%	96.94431968476600%
5h	92.21684202900740%	91.61646536185500%	86.47329346179290%	94.15407278084320%	92.68067290661490%	92.13529041046140%	93.45176097597300%	91.74179228431070%	88.12633608975160%	89.98202022810580%	84.40244523115700%	93.56363106256890%
4h	89.29416719581070%	88.29249970680610%	79.66292408225800%	89.83876540614990%	87.35230760764000%	87.06009198099270%	89.03299544644310%	87.78100162845780%	83.37283643911770%	85.61002746809360%	79.26079811739610%	89.30632078437060%
3h	85.91709227659240%	84.41387351970480%	71.59159761039470%	84.60268797520770%	80.89369763445490%	80.95083204606740%	83.69945292771510%	83.09293079405530%	77.83923281648780%	80.48704908458210%	73.39945394895120%	84.17238885017140%

＜安定電源：純揚水 四国エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.97472360695230%	100.00000000000000%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	99.84469878950850%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.89631978681630%	100.00000000000000%	99.26557885613180%	100.00000000000000%
9h	99.26989853582140%	99.19741860963240%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05207866185740%	99.78779391431080%	97.71778122108250%	100.00000000000000%
8h	97.82813149676130%	98.08117495067850%	98.97075655974840%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.22010182355260%	97.44200042307570%	98.63693434382090%	95.45841811006830%	100.00000000000000%
7h	95.77752309896150%	96.49596781264670%	96.20690683645140%	99.87986029225360%	99.72538765271390%	99.10652238346880%	99.33037652221850%	97.46334900072290%	95.06608449207130%	96.90496707338290%	92.48748952308910%	99.35136567189460%
6h	93.11807334242200%	94.44179719553710%	92.35316865278430%	97.54581524207900%	97.14477311892580%	96.19250556254650%	96.35531708000050%	94.99619830219220%	91.92433145804400%	94.59189210299660%	88.80499546014500%	96.89306901206820%
5h	89.84978222714280%	91.91866309934970%	87.40954200874710%	94.35193959823820%	93.63707107422750%	92.28345195051230%	92.34461728987890%	91.81864972796060%	88.01674111379390%	91.69770943266210%	84.41093592123580%	93.58221533353050%
4h	85.97264975312400%	88.92656552408440%	81.37602690433980%	90.29823336073120%	89.20228151861890%	87.37936154736600%	87.29827715185380%	87.93070327802820%	83.34331346472100%	88.22241906237930%	79.30531090636170%	89.41880463628150%
3h	81.48667592036540%	85.46550446974130%	74.25262333956250%	85.38469652955800%	83.84040445210010%	81.48023435310760%	81.21629666592520%	83.33235895239480%	77.90404851082530%	84.16602099214840%	73.48812041552260%	84.40283692032120%

＜安定電源：純揚水 九州エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.14054286494450%	100.00000000000000%	100.00000000000000%	99.52211416816310%	100.00000000000000%
9h	99.16583333991490%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.26998280126570%	99.05295526039610%	100.00000000000000%	97.43450069337750%	100.00000000000000%
8h	97.11649927128070%	98.30233142321890%	98.91111724567710%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	96.20008928589120%	96.71828926754980%	99.11022728835510%	94.188191199239690%	100.00000000000000%
7h	93.99534164073880%	95.16696196470730%	95.42871311941080%	100.00000000000000%	99.77190111568160%	99.27145735417050%	97.95930474316230%	92.930862311882120%	93.33000725941670%	96.94752447568870%	89.783188061522150%	98.52932642423340%