

2026年度向け 容量市場追加オークション用調整係数

<変動電源：太陽光>

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	3.55156428067414%	11.14626663121740%	9.68688525733926%	11.47591561352340%	16.34928279864920%	12.40053010967740%	13.17670010838200%	15.30557289325650%	7.52758003650076%

<変動電源：風力>

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	22.05804361920360%	31.99707777199530%	24.21122408111180%	27.90200854044020%	21.42908114169300%	28.49201442265110%	19.78033090702620%	32.63796472957840%	19.47846099928300%

<変動電源：一般水力（自流式）>

	北海道	東北	東京	中部	北陸	関西	中国	四国	九州
年間	39.47719972181180%	55.78512636951500%	50.23577383842510%	45.80706061091090%	52.62738304977860%	49.37419815607120%	40.23873873480260%	48.49576030842540%	35.11842944948020%

2026年度向け 容量市場追加オークション用調整係数

2025年4月3日
電力広域の運営推進機関

＜安定電源：純揚水 北海道エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	97.22979702800200%	95.53887519833660%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	99.38227542755810%	99.25522493952910%
19h	97.22979702800200%	95.53887519833660%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	99.38227542755810%	99.25522493952910%
18h	97.22979702800200%	95.53887519833660%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	99.38227542755810%	99.25522493952910%
17h	97.22979702800200%	95.53887519833660%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	99.38227542755810%	99.25522493952910%
16h	97.22979702800200%	95.53887519833660%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	99.38227542755810%	99.25522493952910%
15h	97.22979702800200%	95.53887519833660%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	99.38227542755810%	99.25522493952910%
14h	97.22979702800200%	95.53887519833660%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	99.38227542755810%	99.25522493952910%
13h	97.22979702800200%	95.53887519833660%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	99.38227542755810%	99.25522493952910%
12h	97.22979702800200%	95.53887519833660%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	99.38227542755810%	99.25522493952910%
11h	97.17727068702920%	95.31013910335890%	98.38545396844340%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	99.30334202973580%	99.59848179175020%	98.69798592753740%	99.25522493952910%
10h	96.44204409667470%	94.37024831684920%	97.58734055607260%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.96073490750060%	98.96889706484470%	99.18831156425160%	97.16983929162020%	99.23545769258000%
9h	95.02411725693840%	92.71920283880730%	95.69843660059450%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.02631331108780%	97.83572900330280%	98.08334793351480%	94.79783551980630%	97.99890459448040%
8h	92.92349016782050%	90.35700266923320%	92.71874210200910%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	96.11731323131730%	95.903283784511020%	96.28359089953980%	91.58197461209590%	95.54565645423060%
7h	90.14016282932090%	87.28364780812690%	88.64825706031640%	98.17744566767180%	98.1690968518250%	97.38195426546710%	97.58607593135290%	93.23373466818920%	93.17322359026680%	93.78904046232650%	87.52225656848890%	91.87544084483030%
6h	86.67413524143960%	83.49913825548850%	83.48698147551650%	93.68615276040310%	94.23546089608940%	93.32476196440710%	93.58204948476010%	89.37557762170340%	89.64388623877270%	90.59969662187500%	82.61868138898530%	86.98853019327980%
5h	82.52540740417670%	79.00347401131790%	77.23491534760930%	87.67182771527100%	88.98370492458730%	87.97733045037870%	88.32188674278220%	84.54284209186010%	85.31582579062780%	86.71555937818530%	76.87124907358510%	80.88483369057890%
4h	77.69397931753200%	73.79665507561520%	69.89205867659480%	80.13447053227560%	82.41374177067610%	81.33965972338200%	81.80558770541930%	78.73552807865900%	80.18904224583220%	82.13662873125740%	70.27995962228840%	73.56435133672760%
3h	72.17985098150560%	67.87868144838030%	61.45841146247300%	71.07408121141680%	74.52557143435600%	73.41174978341690%	74.03315237267140%	71.95363558210040%	74.26353560438580%	76.86290468109130%	62.84481303509510%	65.02708313172600%

＜安定電源：純揚水 東北エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	98.10509992785650%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.79375989815930%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	98.10509992785650%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.79375989815930%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	98.10509992785650%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.79375989815930%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	98.10509992785650%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.79375989815930%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	98.10509992785650%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.79375989815930%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	98.10509992785650%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.79375989815930%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	98.10509992785650%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.79375989815930%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	98.10509992785650%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.79375989815930%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	97.86549675124040%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.79375989815930%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	97.37233186847210%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89730078371940%	100.00000000000000%	99.64692675791770%	100.00000000000000%	100.00000000000000%
10h	99.81214103439930%	96.62560527955190%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.84711208806430%	99.80659611316590%	99.05396389597700%	99.31179140317720%	100.00000000000000%
9h	99.11067193207000%	95.6253169847950%	99.36508892973540%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.15366818176900%	98.69735805398560%	98.01487131233730%	98.00256373497170%	99.60608685374290%
8h	97.90881904453950%	94.37146698325510%	97.53841414727630%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	96.81696906483350%	96.87200683223540%	96.52964900699850%	96.09217158749270%	98.37463893409420%
7h	96.20658237180780%	92.86405527587870%	94.75753825896050%	99.99167822750010%	99.53280233840230%	98.76086572721770%	98.63513745602850%	94.83701473725790%	94.33054244791520%	94.59829697996070%	93.58061496074010%	96.51857664731180%
6h	94.00396191387500%	91.10308186235020%	91.02246126478830%	97.51481607461170%	97.14406648311940%	95.86995520316300%	96.11189346746440%	92.21380519904210%	91.07296490102500%	92.22081523122380%	90.46789385471400%	94.03789999339590%
5h	91.30095767074100%	89.08854674266960%	86.33318316475950%	94.12281632683120%	93.91772832645740%	92.02775261103620%	92.77939347386880%	88.94734045018620%	87.09927419156490%	89.39720376078780%	86.75400826941440%	90.93260897234630%
4h	88.09756964240590%	86.82044991683690%	80.68970395887420%	89.81567898415850%	89.85378786841620%	87.23425795083730%	88.63763747524180%	85.03762049069000%	82.40947031953490%	86.12746256865280%	82.43895820484120%	87.20270358416320%
3h	84.39379782886970%	84.29879138485220%	74.09202364713230%	84.59340404659360%	84.95224510899590%	81.48947122256620%	83.68662547158340%	80.48464532055370%	77.00355328493480%	82.41159165481870%	77.52274366099450%	82.84818382884640%

＜安定電源：純揚水 東京エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	97.74403708960140%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	97.74403708960140%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	97.74403708960140%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	97.74403708960140%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	97.74403708960140%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	97.74403708960140%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	97.74403708960140%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	97.74403708960140%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	97.74403708960140%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.59860179313440%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	97.02852279020230%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.84106472380530%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	95.11144860304630%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	94.90207362546490%	99.45554570005420%	98.64835443605550%	100.00000000000000%	100.00000000000000%
9h	100.00000000000000%	91.99281452813340%	99.00986178799020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	90.78162849811330%	97.10757696725740%	95.88961412546300%	97.90761432446210%	100.00000000000000%
8h	97.76743808795580%	87.67262056546360%	95.25294557904810%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	85.47972934175040%	93.25017002771410%	91.81405112605350%	94.20189321510580%	96.88252018391420%
7h	93.59506970465200%	82.15086671503700%	89.63687047376400%	99.24626196049510%	98.3606243349400%	96.73429756051710%	96.22884738977320%	78.99637615637630%	87.8832488142410%	86.42166543782700%	88.95710243279120%	91.94139474373150%
6h	87.86176137494750%	75.42755297685340%	82.16163647213800%	93.45479300713660%	92.22418599790310%	90.37453035894540%	89.79876458060290%	71.33156894199100%	81.00734152838760%	79.71245706078350%	82.17324197751830%	85.24983659748430%
5h	80.56751309884220%	67.50267935091290%	72.82724357417010%	85.59592949980730%	83.97762724006560%	81.97350520025140%	81.34360164127820%	62.48530769859450%	72.62131996860450%	71.68642599492310%	73.85031184928710%	76.80784574517260%
4h	71.71232487633620%	58.37624583721550%	61.63369177986030%	75.66967143850710%	73.62098615998150%	71.53122208443500%	70.86335857179910%	52.45759242618670%	62.72616020207490%	62.34357224024570%	63.98831204809760%	66.61542218679650%
3h	61.29619670742930%	48.04825243576130%	48.58098108920860%	63.67601882323600%	61.15426275765080%	59.04768101149630%	58.35803537216550%	41.24842312476760%	51.32156222879870%	51.68389579675130%	52.58724257394990%	54.67256592235600%

2026年度向け 容量市場追加オークション用調整係数

2025年4月3日
電力広域の運営推進機関

<安定電源：純揚水 中部エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	97.66813882500890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	97.66813882500890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	97.66813882500890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	97.66813882500890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	97.66813882500890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	97.66813882500890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	97.66813882500890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	97.66813882500890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	97.66813882500890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	97.59787526105060%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.84914373431850%	99.09616012324620%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	96.67840402382400%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.47091049222860%	99.40951619408800%	97.10395917184110%	99.68312186482150%	100.00000000000000%
9h	100.00000000000000%	94.90972511332910%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.84034324476400%	98.19068432566830%	94.09874994072900%	98.42211952478190%	100.00000000000000%
8h	98.48145017372630%	92.29183852956570%	98.04975350722250%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.32904286255640%	96.19264812905920%	90.08053242990990%	96.36417081390320%	98.73728929145640%
7h	95.42382090088650%	88.82474427253400%	94.50504637766280%	100.00000000000000%	99.53746663180860%	98.81746682943360%	98.56497372207300%	94.93700934560570%	93.41540760426080%	85.04930663938370%	93.50927573218530%	96.64575876753580%
6h	91.16344679432140%	84.50844234223390%	89.60091507295170%	97.34164828603620%	95.81510577750000%	95.36694472830520%	95.88196875187820%	91.66424269391210%	89.85896275127310%	79.00507256915040%	89.85743427962830%	93.76247418948700%
5h	85.70032785403090%	79.34293273866550%	83.33735959308930%	93.52813983653340%	90.75739193263730%	90.74964863811420%	92.33183250885870%	87.51074290747540%	85.52331357009610%	71.94783021921010%	85.40864645623210%	90.08743555731000%
4h	79.03446408001510%	73.32821546182870%	75.71437993807560%	88.67613064437180%	84.36432509722070%	84.96557855886070%	87.91456499301450%	82.47650998629570%	80.40846006072980%	63.87757958956270%	80.16291226199690%	85.62064287100490%
3h	71.16585547227390%	66.46429051172350%	66.73197610791040%	82.78562070955130%	76.63590527125020%	78.01473449054460%	82.63016620434560%	76.56154393037290%	74.51440222317410%	54.79432068020830%	74.12023169692250%	80.36209613057150%

<安定電源：純揚水 北陸エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	98.99566919338990%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	99.30609471227430%	99.24477809352460%	99.92452484889520%	100.00000000000000%
19h	100.00000000000000%	98.99566919338990%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	99.30609471227430%	99.24477809352460%	99.92452484889520%	100.00000000000000%
18h	100.00000000000000%	98.99566919338990%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	99.30609471227430%	99.24477809352460%	99.92452484889520%	100.00000000000000%
17h	100.00000000000000%	98.99566919338990%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	99.30609471227430%	99.24477809352460%	99.92452484889520%	100.00000000000000%
16h	100.00000000000000%	98.99566919338990%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	99.30609471227430%	99.24477809352460%	99.92452484889520%	100.00000000000000%
15h	100.00000000000000%	98.99566919338990%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	99.30609471227430%	99.24477809352460%	99.92452484889520%	100.00000000000000%
14h	100.00000000000000%	98.99566919338990%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	99.30609471227430%	99.24477809352460%	99.92452484889520%	100.00000000000000%
13h	100.00000000000000%	98.87868928365580%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	99.30609471227430%	99.24477809352460%	99.92452484889520%	100.00000000000000%
12h	100.00000000000000%	98.53457911416280%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	99.30609471227430%	99.24477809352460%	99.92452484889520%	100.00000000000000%
11h	100.00000000000000%	97.96333868491090%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.24189751099240%	98.92931051937710%	99.15761421297660%	99.92452484889520%	100.00000000000000%
10h	99.66043993195200%	97.16496799590010%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.12469703815750%	98.08718033679280%	98.60767822459620%	99.29576364556020%	100.00000000000000%
9h	98.94633999440470%	96.13946704713050%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.40169046856130%	96.77970416452130%	97.59497012838320%	98.01982305757970%	99.64196363955710%
8h	97.85977225156840%	94.88683583860200%	99.85654507964490%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.07287780220400%	95.00688200256270%	96.11948992433770%	96.09670308495370%	98.43059808643430%
7h	96.40073670344330%	93.40707437031470%	95.07175456465030%	100.00000000000000%	99.27180383199960%	100.00000000000000%	99.25027782475350%	95.13825903908540%	92.76871385091690%	94.18123761245960%	93.52640372768240%	96.60788473090890%
6h	94.56923335002930%	91.70018264226840%	88.14136474734680%	97.20118733908190%	96.95104201233590%	94.68032471617110%	97.07480230076980%	92.59783417920570%	90.06519970958400%	91.78021319274900%	90.30892498576550%	94.17382357298070%
5h	92.36526219132630%	89.76616065446340%	79.06537562773450%	93.03674735804840%	93.81643747826330%	86.78562144673780%	94.16545597189840%	89.45160322256480%	86.89633957856400%	88.91641666520590%	86.44426685920320%	91.12841461264980%
4h	89.78882322733450%	87.60500840689940%	67.84378720581340%	87.72575560712610%	89.86799022978180%	76.72205327546400%	90.52223883813930%	85.69956616916270%	83.26213345785680%	85.58984802983020%	81.93242934799540%	87.47165784991630%
3h	86.83991645805380%	85.21672589957660%	54.47659948158340%	81.26821208631510%	85.10570026689150%	64.48962020234970%	86.14515089949230%	81.34172301899940%	79.16258134746250%	81.80050728662200%	76.77341245214220%	83.20355328478000%

<安定電源：純揚水 関西エリア>

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
19h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
18h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
17h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
16h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
15h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
14h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
13h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
12h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
11h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
10h	100.00000000000000%	98.27647139498020%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.73201076557780%	99.90196738716840%	100.00000000000000%	100.00000000000000%	100.00000000000000%
9h	99.57664310940070%	97.5619762614220%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.03626166360660%	98.51691843744740%	98.21430696441960%	98.5531758867850%	100.00000000000000%
8h	98.32847192403700%	95.77713496685110%	98.29741844607700%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.28220281135550%	96.53353476943190%	95.56960870731630%	96.30465158471490%	98.97969311609770%
7h	96.3863763244290%	92.92194751060690%	94.24941057109360%	100.00000000000000%	99.71227295521190%	98.98902270301700%	98.74314330571540%	94.46983420882460%	93.68957830597960%	91.80421932942690%	93.13480406669830%	96.66558145919350%
6h	93.75035636461860%	88.99641389290960%	88.58797106418270%	97.01730867413420%	95.66667830398510%	95.04384970024020%	95.63796471199930%	90.59915585601400%	89.98504904709060%	86.91813883075140%	89.04363333282870%	93.42223918967650%
5h	90.42041199056400%	84.00053411375920%	81.31309992534450%	92.54051647823990%	90.15038338330590%	89.73201008903440%	91.49379048408690%	85.67016775292360%	85.41994699276490%	80.91136721128980%	84.03113938310620%	89.24966630754670%
4h	86.39654322027910%	77.93430817315580%	72.42479715457890%	86.82638136477980%	83.16338819317410%	83.05350386939990%	86.31062062197810%	79.68286989955340%	79.99427214300250%	73.78390447104210%	78.09732221753070%	84.14786281280400%
3h	81.67875005376390%	70.79773607109920%	61.92306275188580%	79.8749033375370%	74.70569273359000%	75.00833104133640%	80.08845512567300%	72.63726229590350%	73.70802449780340%	65.53575061000840%	71.24218183610230%	78.11682870544850%

2026年度向け 容量市場追加オークション用調整係数

2025年4月3日
電力広域の運営推進機関

＜安定電源：純揚水 中国エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	99.96080109014990%	98.25870182875840%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
19h	99.96080109014990%	98.25870182875840%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
18h	99.96080109014990%	98.25870182875840%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
17h	99.96080109014990%	98.25870182875840%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
16h	99.96080109014990%	98.25870182875840%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
15h	99.96080109014990%	98.25870182875840%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
14h	99.96080109014990%	98.25870182875840%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
13h	99.96080109014990%	98.14893977500290%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
12h	99.96080109014990%	97.81234513323890%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
11h	99.96080109014990%	97.24891790346640%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.05276893723880%	99.71239884797000%	99.90709035321070%	100.00000000000000%	100.00000000000000%
10h	99.63523972158740%	96.45865808568540%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.04949568067100%	99.18013072784310%	99.66006090022350%	99.44054634583750%	100.00000000000000%
9h	98.88766398936350%	95.44156567989590%	99.64622457278920%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.37085842661960%	97.99148713947390%	98.68911673581850%	98.16242071300130%	99.68826020371480%
8h	97.71807389347840%	94.19764068609780%	97.72546381309440%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	97.01685717508440%	96.14646808286240%	96.99425785999570%	96.23164190448730%	98.44179766814960%
7h	96.12646943393190%	92.72688310429130%	94.73562047108500%	99.97342431645720%	99.79240987575020%	98.72431755712150%	98.43073666164730%	94.98749192606560%	93.64507355800880%	94.57548427275530%	93.64820992029550%	96.52372301222690%
6h	94.11285061072420%	91.02929293447620%	90.67669454676100%	97.55169463864430%	96.78658649163710%	95.74400198010250%	95.93233517879630%	92.28276267956300%	90.48730356491290%	91.43279597409700%	90.41212476042590%	93.93403623594650%
5h	91.67721742385510%	89.10487017665260%	85.54868604012230%	94.23691558274910%	92.68747916485100%	91.77940832307360%	92.64366746646230%	88.90266943557680%	86.67315810357480%	87.56619296402100%	86.52338642487850%	90.67273733930850%
4h	88.81956987332470%	86.95361483082050%	79.35159495116900%	90.02908714877150%	87.49508789539180%	86.83053658603460%	88.56473352464540%	84.84721219410680%	82.20263717399440%	82.97567524252730%	81.98199491365340%	86.73982632231290%
3h	85.53990795913290%	84.57552689697990%	72.08542127990100%	84.92820933671160%	81.20941268325960%	80.89738676898550%	83.69553335334550%	80.11639095515310%	77.07574077617180%	77.66124280961580%	76.78795022675050%	82.13530318495970%

＜安定電源：純揚水 四国エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	98.24174747550700%	98.71722467038660%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.72556452512820%	100.00000000000000%	100.00000000000000%
19h	98.24174747550700%	98.71722467038660%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.72556452512820%	100.00000000000000%	100.00000000000000%
18h	98.24174747550700%	98.71722467038660%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.72556452512820%	100.00000000000000%	100.00000000000000%
17h	98.24174747550700%	98.71722467038660%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.72556452512820%	100.00000000000000%	100.00000000000000%
16h	98.24174747550700%	98.71722467038660%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.72556452512820%	100.00000000000000%	100.00000000000000%
15h	98.24174747550700%	98.71722467038660%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.72556452512820%	100.00000000000000%	100.00000000000000%
14h	98.24174747550700%	98.67350510829530%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.72556452512820%	100.00000000000000%	100.00000000000000%
13h	98.19726290164580%	98.42237577259970%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.72556452512820%	100.00000000000000%	100.00000000000000%
12h	97.79265777497110%	97.96383666329970%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.72556452512820%	100.00000000000000%	100.00000000000000%
11h	97.02793209548290%	97.29788778039530%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.97733703372800%	99.59716806591350%	99.69764135413270%	99.97899559275790%	100.00000000000000%
10h	95.90308586318130%	96.42452912388650%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.89230793976580%	99.05325241833290%	99.16443297015060%	99.28966190956070%	100.00000000000000%
9h	94.41811907806610%	95.34376069377350%	99.14938478620750%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	98.16908206915800%	97.86091231781650%	98.12593937318190%	97.99448166757130%	99.51912156851060%
8h	92.57303174013750%	94.05558249005600%	97.36990511533230%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	96.80765942190450%	96.02014776436420%	96.58216056322660%	96.09345486678970%	98.26456291003200%
7h	90.36782384939550%	92.55999451273420%	94.72967864389090%	99.89629231417860%	99.53568943231530%	98.62045792968770%	98.41903322864020%	94.80803999800540%	93.53095875797610%	94.53309654028480%	93.58658150721590%	96.37667505793270%
6h	87.80249540583990%	90.85699676180800%	91.22870537188330%	97.68108625745880%	97.07720166937270%	95.87926915602020%	95.64248856704100%	92.17022379746070%	90.39334529865220%	91.97874730435650%	90.47386158884990%	93.85545801221270%
5h	84.87704640947080%	88.94658923727750%	86.86698529930940%	94.65734420960570%	93.75491827776390%	92.25338267717860%	91.97364154917670%	88.89421082027030%	86.60730738639250%	88.91911285544160%	86.75529511169160%	90.70091177287200%
4h	81.59147686028830%	86.82877193914260%	81.64451842616920%	90.82506617061920%	89.56883925748890%	87.74279849316280%	87.41249217504730%	84.98000106643430%	82.17284502119690%	85.35419319354010%	82.43088207574120%	86.91303633991060%
3h	77.94578675829230%	84.50354486740340%	75.56130475246290%	86.18425214049930%	84.51896460854770%	82.34751660397280%	81.95904044465260%	80.42759453595260%	77.08995820306550%	81.28398831865210%	77.50062248099860%	82.49183171332850%

＜安定電源：純揚水 九州エリア＞

	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
20h以上	97.99202809923430%	97.39572591340520%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.44539906065640%	99.83958145990020%	99.99842557774680%	100.00000000000000%	100.00000000000000%
19h	97.99202809923430%	97.39572591340520%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.44539906065640%	99.83958145990020%	99.99842557774680%	100.00000000000000%	100.00000000000000%
18h	97.99202809923430%	97.39572591340520%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.44539906065640%	99.83958145990020%	99.99842557774680%	100.00000000000000%	100.00000000000000%
17h	97.99202809923430%	97.39572591340520%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.44539906065640%	99.83958145990020%	99.99842557774680%	100.00000000000000%	100.00000000000000%
16h	97.99202809923430%	97.39572591340520%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.44539906065640%	99.83958145990020%	99.99842557774680%	100.00000000000000%	100.00000000000000%
15h	97.99202809923430%	97.39572591340520%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	100.00000000000000%	99.44539906065640%	99.83958145990020%	99.99842557774680%	100.00000000000000%	100.000000000000